



7 April 2014

Karu Wijayasinghe  
Senior Strategic Land Use Planner  
Hawkesbury City Council  
PO Box 146  
Windsor NSW 2756

Hawkesbury City Council

10 APR 2014

Dear Karu

**Notification of Planning Proposal to rezone Lot 1 DP 700263, Lot 2 DP 700263, Lot C DP 160847, Lot 2 DP 629053 and Lot 3 DP 700263, 120 -188 Hawkesbury Valley Way, Clarendon to B7 Business Park**

Thank you for your letter dated 17 March 2014 regarding the above planning proposal.

Endeavour Energy has zone substation capacity to supply this new business park, however would require a new 11kV feeder from Windsor zone substation. Endeavour Energy has funding policies based on user pays principles for connection works.

It is important that arrangements for the supply of electricity to the Business Park development are determined in a timely manner. In this regard, the developer or their representative should contact Endeavour Energy's Network Connections Branch on 133 718.

We look forward to liaising with the developers to ensure electricity supply can be delivered in a timely and efficient manner.

Yours faithfully

 8/4/2014

Jason Lu  
Capacity Planning Manager  
Asset & Network Planning  
Endeavour Energy

In reply quote: 20140407/001



SCANNED